TAMIL NADU FIRE & RESCUE SERVICE DEPARTMENT
FIRE LICENSE RENEWAL

(Under Section 13 of the Tamil Nadu Fire Service Act 1985 and with Tamil Nadu Fire & Rescue Service Rules-1990- Appendix-III)

L.DisNo :0541/A1/2025 **Date : 18-02-2025**
Online No: 0491-2025

License is hereby granted Under Section 13 of the Tamil Nadu Fire & Rescue Service Act 1985 for Selling / Storing / Manufacturing / Pressing / Processing / Transporting of Fireworks / Crackers / Petroleum Items /L.P.G Cylinders/Explosives/Other Items of Process EDUCATION of **M/S ADHIYAMAN EDUCATIONAL AND RESEARCH INSTITUTIONS.,** consists of ACE Admin Block, PG Block, Mechanical Block, Civil, B.Arch & Biotech Block, M.G.R College Arts & Science, Adhiyaman Polytechnic College Block, Pennar Boys Hostel Block, Bhavani Girls Hostel block and Cauvery Hostel-The Continental Enterprises-TEPL with the jurisdiction of premises Chennathur Village S.F.NO: 533/1A, 520, 521, 535 537, 536/2, 538, 542/1, 536/1, 537, 535, 523, 545/2, 545/1, 525, 543, 521, 522, 545/1, 511/1, 513, 517/1, 513, 517/1, 514/1, 515/1, 511/2, 514/3A, 511/1, 514/3B, 511/1, 515/2, 514/2, 523, 524/2, 524/1, 525, 516, 522, 509/2, 509/1B, 506/3, 512, 509/1A, 510/2, 510/1A, 510/1B, 506, 505, 506, 512, 505/1&2, 496/1, 498, 502/2, 496/2, 502/1, 503, 504, 506, 504, 504 Thorapalli Agraharam Village S.F. NO: 86/1A, 85/1, 84/2, 87/2, 87/4B, 39/2H, 39/2, 39/21, 39/2K, 39/2L 39/2J, 39/2N, 39/2, 84/2, 84/4, 87/1, Moranapalli Village, S.F.NO: 302/3, 302/3, 83/1, 302/1, 8/2, 1/2, Hosur Taluk, Krishnagiri District, Tamil Nadu Subject to the Conditions noted thereon and other conditions as may be prescribed.

This Premise is inspected by District Officer, Krishnagiri on 15. 02. 2025.

1) The Existing Fire Fighting Equipments / Extinguishers should always be kept in working condition.
2) The Emergency Exit should be open always during the Working Time.
3) The Emergency Light should be used at the time of power failure.
4) All Fire prevention and Fire Precautionary measures should be adapted.
5) Fire Drill and Evacuation Drill Should be conducted periodically Along with the local fire Brigade.
6) In Compliance to Section 3, 2 of BIS 12459:1988 – Code of Practice for Fire Safety in Cable Regularization, a transparer Fire retardant coating of 1 meter shall be applied on all electrical cables at both sides of termination points in every electrical panel and all the cables in the Distribution Box.

Digitally signed by M.VELU
DN: cn=M.VELU, o=Fire And Rescue Services, ou=District Officer, email=districtfireoffice@gmail.com, c=US
Adobe Acrobat Reader version: 2024.005.20399

DISTRICT OFFICER,
Fire and Rescue Service,
Krishnagiri District.

To :
M/S ADHIYAMAN EDUCATIONAL AND RESEARCH INSTITUTIONS,
M, G, R Nagar,
Hosur Taluk,
Krishnagiri District,
TamilNadu.

ANANCHAPERUMAL MUTHUMONI
Digitally signed by ANANCHAPERUMAL MUTHUMONI
Date: 2025.03.15 09:02:01 +05'30'